


7 > CONDITION OF SAFETY STANDARD(UL, C-UL, TUV STANDARD)

7 FIG1. PANEL CUTOUT



7 FIG2. PANEL CUTOUT




TABLE 1. UL, C-UL CONDITION

	CONDITION 1	CONDITION 2		
CURRENT VOLTAGE(AC/DC)	600V			
CURRENT RATING	100A	150A		
CABLE	14 TO 22sq(※1)	38 TO 50sq(※1)		
CREEPAGE DISTANCE(%2)	MIN:3.2mm			
CLEARANCE DISTANCE(※2)	MIN:3.2mm			

TABLE 2. TUV CONDITON

	CONDITION I	CONDITION II	
CURRENT VOLTAGE(AC/DC)	800V	600V	
	100A(CABLE 14	1 TO 22sq ※1)	
CURRENT RATING	125A(CABLE 38sq ※1)		
	150A(CABLE 50sq ※1)		
OVER VOLTAGE CATEGORY	II	Ш	
POLLUTION DEGREE	3		
CREEPAGE DISTANCE(※2)	MIN:12.6mm	MIN:12.6mm	
CLEARANCE DISTANCE(%2)	MIN:6mm	MIN:6mm	
INSULATION SYSTEM	BASIC INSULATION		
	(PANEL HAS THE EARTH)		

		CONDITION III	
	CURRENT VOLTAGE (AC/DC)	1000V	
		100A(CABLE 14 TO 22sq ※1)	
	CURRENT RATING	125A(CABLE 38sq ※ 1)	
2		150A(CABLE 50sq ※1)	
	OVER VOLTAGE CATEGORY	Ш	
	POLLUTION DEGREE	3	
	CREEPAGE DISTANCE(※2)	MIN:16mm	
	CLEARANCE DISTANCE(※2)	MIN:8mm	
	INSULATION SYSTEM	BASIC INSULATION	
		(PANEL HAS THE EARTH)	

№1: AS SCREWS AND CRIMP TERMINAL ATTACHED WITH POWER CONTACT HAVE AN IMPACT ON THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE, PLEASE USE RECOMMENDED SCREWS AND CRIMP TERMINALS. IN CASE YOU USE CABLES OTHER THAN FOLLOWING RECOMMENDED SCREWS AND CONTACTS, PLEASE BE CAREFUL THAT THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE MEET THE STANDARD OF UL, C-UL, TUV.

№2: THE COVERAGE OF THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE IS AS FOLLOWS.

-BETWEEN CRIMP TERMINALS

FORM HC0011-5-8 1

- -BETWEEN POWER CONTACT AND PANEL
- -BETWEEN CRIMP TERMINAL AND PANEL
- -BETWEEN SCREWS (ATTACEHD WITH POWER CONTACT) AND PANEL

- 1. THE MATING PARTNER OF THIS PRODUCT IS PS3-2US(**)(CL236-1041-0-**).
 - 2 PLEASE SET THE DISTANCE BETWEEN PANELS AS 24.2 TO 26.2mm.
 - T3>THE TIGHTINING TORQUE FOR THE SCREW ATTACHED WITH REF NO. ② IS 2.5 TO 5.2 N⋅m. THE RECOMMENDED SCREW AND TERMINAL IS AS FOLLOWS.
 - -RECCOMEDNED SCREW: JIS B 1188 SPRING WASHER + CROSS RECESSED PAN HEAD SCREW WITH CAPTIVE POLISHED CIRCULAR WASHER M6 imes 12
 - -RECOMMENDED CRIMP TERMINAL

CABLE 14sq : JIS C 2805 R14-6 CABLE 22sq : JIS C 2805 R22-6

- APROVED BY THE CONDITION OF TABLE 3. SAFETY STANDARD IS DEFERRENT UP TO THE APPLIED RATED VOLTAGE AND CURRENT PLEASE SEE THE TABLE 1 AND TABLE 2.
 - 8. THE POWER CONTACT OF THIES PRODUCT IS NOT APPLICABLE FOR HOT-SWAP. IT CAN NOT BE USED TO INTERRUPT THE POWER.

HRS	DRAWING NO.	EDC-128048-11-00	
	PART NO.	PS3-2UP(11)	
	CODE NO.	CL0236-1042-2-11	\triangle $2/2$